

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. 1143

Dated: 07/11/2025

It is certified that an inspection team headed by :- **Divisional Sanitary Inspector**
(Name of Officers with designation) from :- **Mr. Sanjay Darade (Dsi)**
Name of Department/ Office) inspected the:- **Solid Waste Management Dept.**
(Panchavati Div). **Godavari Public School,, Adr- Gat No. 772/1, Adgaon - 2, Tal.**
Dist. Nashik - 422004. on **27.10.2025** checked the water test report submitted by the
school and found that the school has potable drinking water for students and staff of the
institution and is having provision for running water in the toilets and maintaining
hygienic sanitation condition in the school building & the campus as per norms
prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of :- **For One year**



Signature with Seal:

Name: Ajit Nikat

Designation: Director S. Sanitary Dept.

Name & Address of the Office / Department

(Signature)
उपस्थायित तथा संचालक
स्वास्थ्य विभाग
नाशिक महानगरपालिका नाशिक

To,
Godavari Public School,
Adr- No. 772/1, Adgaon - 2,
Tal. Dist., Nashik - 422004

True Copy

(Signature)
Principal
Godavari Public School, Nashik

(Signature)
Manager
Godavari Public School, Nashik

GOVERNMENT OF MAHARASHTRA
JUNIOR SCIENTIFIC OFFICER
DISTRICT PUBLIC HEALTH LABORATORY, NASHIK
 Civil Hospital Campus, Trimbak Road, Nashik-422 001.



Office Phone No.:- 0253 2570613

Email:-dphlnasik@gmail.com

NO. DPHL/NSK/WC/ W-388/ 4733/2026

Date:- 04/9/2026

HEALTH SERVICES

REPORT ON CHEMICAL EXAMINATION OF WATER SAMPLE FOR DRINKING PURPOSES

Name of Senders:	GODAVARI PUBLIC SCHOOL, Gat No. 772/1, Adgaon-2, Tal. Dist. Nashik- 422 004.				
Letter No.:	2026-27/0038	Dated:	07/08/2026	Collected by:	Customer
Govt. Receipt No.:	5148610	Fees:	940/-	Date of Receipt:	12/08/2026
Date of Received:	12/08/2026	Date of Examination:	12/08/2026	Date of Reporting:	01/09/2026

All Analytical results are in mg per litre (except pH & Turbidity)

Sample No.:	01	Method of Test as per IS 3025	BIS Specification IS 10500: 2012 Normal values	
Sample ID/Lab. Ref. No.:	W-388			
Source:	Filter Water			
Address/Location of Source:	Adgaon-2, Nashik 422 004.			
Date of collection:	12/08/2026	Method of Test as per IS 3025	Acceptable limits	Permissible limits
Sr. No.	Name of Test			
01	Physical Appearance		Clear, Colorless,	
02	Odour		Agreeable	
03	pH Value		7.8	
04	Turbidity (N.T.U.)		0.74	
05	Chlorides (as Cl)		20.0	
06	Total Hardness (as CaCO ₃)		92.0	
07	Total Alkalinity (as CaCO ₃)		62.9	
08	Total Dissolved Solids		160.0	
09	Fluoride (as F)		0.15	
10	Iron (as Fe)		0.01	
11	Nitrate (as NO ₃)		6.58	
12	Permanent Hardness		29.1	

MARK

Sample No. 01 is chemically fit for drinking purpose on the basis of analyzed parameters only. However, this/these water source(s) can be used for drinking purpose only after proper treatment, disinfection and ascertaining their bacteriological quality frequently or regularly.

Forwarded with compliments to:

GODAVARI PUBLIC SCHOOL,
 Gat No. 772/1, Adgaon-2, Tal. Dist. Nashik- 422 004

Bayam
Junior Scientific Officer
 District Public Health Laboratory,
 Nashik.
 Authorized Signatory

True Copy

Jeena
Principal
 Godavari Public School, Nashik

Jeena
Manager
 Godavari Public School, Nashik

Note:

- It is presumed that the representative sample(s) is/are collected from the original source and sent for analysis.
- This report is restricted to the sample(s) submitted and test performed in the laboratory.
- This sample(s) is/are not collected by this laboratory.
- Any changes to this test report are not allowed by this laboratory.
- This test report may not be reproduced in part, without the permission of this laboratory.

*** End of Report ***



JUNIOR SCIENTIFIC OFFICER

DISTRICT PUBLIC HEALTH LABORATORY, NASHIK.

Civil Hospital Campus, Trimbak Road, Nashik - 422001

E-mail: dphlnasik@gmail.com

Phone:- 0253-2570613

• REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE •

Sender's Name:- ✓ GODAVARI PUBLIC SCHOOL, NASHIK.

Address :- Gat No. 772/1, Adgaon - 2, Tal. Dist. Nashik - 422004.

Senders Letter No. & Date :- 12-08-2026

Date of Sample Collection :- 12-08-2026 Laboratory Reference No. :- 08 / 695 / 67

Date of Arrival at Laboratory :- 12-08-2026

Date of Commencing Examination:- 12-08-2026

Sr. No.	Particulars of Water Samples	Results of Analysis (As per IS 10500:2012)			Remark
		Most Probable Number of bacteria Per 100 ml.			
		Coliforms	Thermotolerant coliforms	<u>E.coli</u>	
1	R O Filtered Water (NMC)	0	0	--	<u>Potable</u>
Receipt No :- 5148610		Fee Rs. :- 940/-			Date:- 12-08-2026
Note :- Result/ Report mentioned above is/are of sample/s submitted to this laboratory only.					
Remark :- Above Water Sample No. 1 is bacteriologically <u>FIT</u> for drinking purpose . However it/they can be used only after proper filtration, chlorination and retesting its bacteriological quality.					

Outward No:- 4458/2026

Date:- 24.08.2026

Beyan
 Junior Scientific Officer
 District Public Health Laboratory,
 Nashik.

Prerna
 Manager
 Godavari Public School, Nashik

True Copy

Prerna
 Principal
 Godavari Public School, Nashik