

GOVERNMENT OF MAHARASHTRA
JUNIOR SCIENTIFIC OFFICER
DISTRICT PUBLIC HEALTH LABORATORY, NASHIK
 Civil Hospital Campus, Trimbak Road, Nashik-422 001.



Office Phone No.:- 0253 2570613

Email:-dphlnasik@gmail.com

NO. DPHL/NSK/WC/ W-388/ 4733/2026

Date:- 04/9/2026

HEALTH SERVICES

REPORT ON CHEMICAL EXAMINATION OF WATER SAMPLE FOR DRINKING PURPOSES

Name of Senders:	GODAVARI PUBLIC SCHOOL, Gat No. 772/1, Adgaon-2, Tal. Dist. Nashik- 422 004.				
Letter No.:	2026-27/0038	Dated:	07/08/2026	Collected by:	Customer
Govt. Receipt No.:	5148610	Fees:	940/-	Date of Receipt:	12/08/2026
Date of Received:	12/08/2026	Date of Examination:	12/08/2026	Date of Reporting:	01/09/2026

All Analytical results are in mg per litre (except pH & Turbidity)

Sample No.:		01	Method of Test as per IS 3025	BIS Specification IS 10500: 2012 Normal values	
Sample ID/Lab. Ref. No.:		W-388			
Source:		Filter Water			
Address/Location of Source:		Adgaon-2, Nashik 422 004.			
Date of collection:		12/08/2026			
Sr. No.	Name of Test	Test Result		Acceptable limits	Permissible limits
01	Physical Appearance	Clear, Colorless,	----	-----	-----
02	Odour	Agreeable	Part 5	Agreeable	Agreeable
03	pH Value	7.8	Part 11	6.5 to 8.5	No relaxation
04	Turbidity (N.T.U.)	0.74	Part 10	1.0	5.0
05	Chlorides (as Cl)	20.0	Part 32	250	1000
06	Total Hardness (as CaCO ₃)	92.0	Part 21	200	600
07	Total Alkalinity (as CaCO ₃)	62.9	Part 23	200	600
08	Total Dissolved Solids	160.0	Part 16	500	2000
09	Fluoride (as F)	0.15	Part 60	1.0	1.5
10	Iron (as Fe)	0.01	Part 53	1.0	No relaxation
11	Nitrate (as NO ₃)	6.58	Part 34	45	No relaxation
12	Permanent Hardness	29.1	----	-----	-----

MARK

Sample No. 01 is chemically fit for drinking purpose on the basis of analyzed parameters only. However, this/these water source(s) can be used for drinking purpose only after proper treatment, disinfection and ascertaining their bacteriological quality frequently or regularly.

Forwarded with compliments to:

GODAVARI PUBLIC SCHOOL,
 Gat No. 772/1, Adgaon-2, Tal. Dist. Nashik- 422 004

Bayam
Junior Scientific Officer
 District Public Health Laboratory,
 Nashik.
 Authorized Signatory

True Copy

Jeena
Principal
 Godavari Public School, Nashik

Jeena
Manager
 Godavari Public School, Nashik

Note:

- It is presumed that the representative sample(s) is/are collected from the original source and sent for analysis.
- This report is restricted to the sample(s) submitted and test performed in the laboratory.
- This sample(s) is/are not collected by this laboratory.
- Any changes to this test report are not allowed by this laboratory.
- This test report may not be reproduced in part, without the permission of this laboratory.

*** End of Report ***



JUNIOR SCIENTIFIC OFFICER

DISTRICT PUBLIC HEALTH LABORATORY, NASHIK.

Civil Hospital Campus, Trimbak Road, Nashik - 422001

E-mail: dphlnasik@gmail.com

Phone:- 0253-2570613

• REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE •

Sender's Name:- ✓ GODAVARI PUBLIC SCHOOL, NASHIK.

Address :- Gat No. 772/1, Adgaon - 2, Tal. Dist. Nashik - 422004.

Senders Letter No. & Date :- 12-08-2026

Date of Sample Collection :- 12-08-2026 Laboratory Reference No. :- 08 / 695 / 67

Date of Arrival at Laboratory :- 12-08-2026

Date of Commencing Examination:- 12-08-2026

Sr. No.	Particulars of Water Samples	Results of Analysis (As per IS 10500:2012)			Remark
		Most Probable Number of bacteria Per 100 ml.			
		Coliforms	Thermotolerant coliforms	<u>E.coli</u>	
1	R O Filtered Water (NMC)	0	0	--	<u>Potable</u>
Receipt No :- 5148610		Fee Rs. :- 940/-			Date:- 12-08-2026
Note :- Result/ Report mentioned above is/are of sample/s submitted to this laboratory only.					
Remark :- Above Water Sample No. 1 is bacteriologically <u>FIT</u> for drinking purpose . However it/they can be used only after proper filtration, chlorination and retesting its bacteriological quality.					

Outward No:- 4458/2026

Date:- 24.08.2026

Beyan
 Junior Scientific Officer
 District Public Health Laboratory,
 Nashik.

True Copy

Jeena
 Principal
 Godavari Public School; Nashik

Jeena
 Manager
 Godavari Public School, Nashik